

SECTION 055133

METAL LADDERS

Note to Specifier This specification contains component and configuration options.

Where indicated, choose the appropriate choice for your specific project requirements

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

- 1. [Single Safety Gates] [Full Height Safety Gates] [and] [Paired Safety Gates] Specialty custom designed, spring assisted, self-closing Safety Gates for walk through fixing ladders, floor and wall openings, holes.
- 2. Gate Hardware.

B. Related Sections:

- 1. Division 05 Metal Ladders.
- 2. Division 05 Pipe and Tube Railings.
- 3. Division 05 Structural Steel Framing.

1.2 SUBMITTALS

- A. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation instructions.
- B. Shop Drawings: Provide shop drawings showing layout, profiles, and product components, including anchorage, hardware, and finishes. Include dimensional plans, applicable material specifications, elevations and sections detailing mounting and connections.
 - 1. Contractor to provide manufacturer with field measurements and mounting structure prior to commencement of shop drawings.

1.3 CLOSEOUT SUBMITTALS

A. Provide Operation and Maintenance data to include methods for maintaining installed products, precautions against cleaning materials and methods detrimental to finishes and performance.

Rev. Date: 02.05.21 Page 1 of 6











1.4 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer must demonstrate a minimum of five (5) years successful experience in design and manufacture of similar related closures. Upon request, provide supporting evidence including list of installations, descriptions, name, and method of contact.
- B. Minimum Qualifications: Manufacturer must demonstrate compliance and certification of a Quality Management System administered by the International Organization for Standardization (ISO). Documentation of current certification status to be provided upon request.
- C. Welder Qualifications: Welders Certified in accordance with American Welding Society Procedures for applicable material used in production of specified product.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging container with identification markings intact until ready for installation.
- B. Protect materials from exposure to moisture during storage.
- C. Store materials in a dry, warm, ventilated weathertight location. If outdoor storage is required, block materials to store at an incline, to prevent pooling of any moisture and promote runoff. Tarp materials in a tent-like arrangement, elevated above the product with open sides to allow airflow. Store loose or high value components in a dry, controlled environment.
- D. Use caution when unloading and handling product to avoid bending, denting, crushing, or other damage to the product.
- E. When using forklifts, use forks of proper length to fully support product being moved. Consult "Approved for Construction" drawings or consult with factory for proper lift points.


1.6 PROJECT CONDITIONS

A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's indicated limits.

1.7 COORDINATION

- A. Conduct site survey and provide to manufacturer, prior to manufacturer's commencement of shop drawings, the actual site conditions of the mounting location, to include; material type, dimensions and configuration, interferences with mounting surface, or any other condition that may impact the ability of the gate to be properly installed.
- B. Coordinate work with other operations and installation of adjacent materials to avoid damage.

Rev. Date: 02.05.21 Page 2 of 6











1.8 WARRANTY

A. Manufacturer's Standard Warranty: Product to be free from defects in material and workmanship for a period of one (1) year from date of shipment.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

A. Intended as a visible and physical continuation of adjacent railing systems at elevated openings where required by U.S. Federal OSHA at time of manufacture. Product designed to meet or exceed U.S. Federal requirements of dimensions and load requirements at time of manufacturing.

2.2 LADDER SAFETY GATE

- A. Description: Hinged, Ladder Safety Gate including Gate Arm, Pivot Clamp Bracket, Hinge Plate, Hinge Spring, and hardware.
 - 1. Approved Manufacturer: PS Safety AccessTM, which is located at: 1150 S. 48th Street, Grand Forks, ND 58201; Toll Free Tel: 877.446.1519; Email: 4info@psindustries.com; Web: www.pssafetyaccess.com or www.psindustries.com
 - a. Basis of Design Product: Model: LSG/ LSGF/DBL LSG.
- B. Substitutions: Not permitted.
- C. Single Source Responsibilities: Obtain all safety gate from single manufacturer.

2.3 EQUIPMENT


A. Products Details:

- 1. The Ladder Safety Gate is a railing continuation, self-closing swing gate.
 - a. Model/Min/Max Opening Width:

LSG	OPENING WIDTH	
MODEL #	MIN	MAX
LSG-15	13 ¾"	17 ½"
LSG-18	16 ¾"	20 ½"
LSG-21	19 ¾"	23 ½"
LSG-24	22 ¾"	26 ½"
LSG-27	25 ¾"	29 ½"
LSG-30	28 ¾"	32 ½"

DBL LSG	OPENING WIDTH	
MODEL #	MIN	MAX
DBL LSG-9	18"	22 ½"
DBL LSG-12	22"	28 ½"
DBL LSG-15	28"	34 ½"
DBL LSG-18	34"	40 ½"
DBL LSG-21	40"	46 ½"
DBL LSG-24	46"	52 ½"

Rev. Date: 02.05.21











LSG	OPENING WIDTH	
MODEL#	MIN	MAX
LSG-33	31 3/4"	35 ½"
LSG-36	34 3/4"	38 ½"
LSG-40	38 ¾"	42 ½"
LSG-44	42 3/4"	46 1/2"
LSG-48	46 3/4"	50 ½"

LSGF	OPENING WIDTH	
MODEL #	MIN	MAX
LSGF-18	16 3/4"	20 ½"
LSGF-21	19 ¾"	23 ½"
LSGF-24	22 3/4"	26 ½"
LSGF-27	25 ¾"	29 ½"
LSGF-30	28 ¾"	32 ½"
LSGF-33	31 3/4"	35 ½"
LSGF-36	34 ¾"	38 ½"

2.4 MATERIALS

- A. Ladder Safety Gate to be fabricated from the following type of material;
- **Note to Specifier** Choose one (1) of the following materials.
 - 1. Steel: Commercial quality, low carbon structural or formed shapes, tubing, and bars of appropriate size and strength with welded construction.
 - 2. Stainless Steel: Type 304 structural or formed shapes, tubing, and bars of appropriate size and strength with welded construction.
 - 3. Stainless Steel: Type 316 structural or formed shapes, tubing, and bars of appropriate size and strength with welded construction.
 - B. Gate Arm to be manufactured of the same material type and finish as Ladder Safety Gate.
 - 1. Formed $1 \frac{1}{4}$ " square, 11-gauge tubing with minimum of $3-\frac{3}{4}$ " $(-1-\frac{1}{4}$ " to $+2-\frac{1}{2}$ ") of adjustment.
 - C. Pivot Clamp Bracket to be manufactured of the same material type and finish as Ladder Safety Gate.
 - 1. Formed 10-gauge universal bracket to fit railings up to 2" O.D.
 - 2. Adaptable to flat surfaces and welded installation.
 - D. Hinge Plate to be manufactured of the same material type and finish as Ladder Safety Gate.
 - 1. 10-gauge plate to provide for gate arm adjustment of 3 $\frac{3}{4}$ " (-1- $\frac{1}{4}$ " to +2- $\frac{1}{2}$ ") inches
 - E. Hinge Springs to be torsion type, Stainless Steel.
 - 1. Provide two (2) springs per gate, housing within hinge pivot.
- **Note to Specifier** Any model number higher than LSG-36 will have: Hinge and Pivots, three (3), torsion type, stainless, springs per gate, housed within hinge pivot.
 - F. Placards: Factory mounted, caution labels with graphic fall hazard symbol and the statement "Safety First". Shall be safety yellow background color with black graphics.

Rev. Date: 02.05.21 Page 4 of 6











G. Mounting Hardware: Provide zinc plated U-bolts, minimum .312" diameter, to accept railing posts up to 2" diameter, and locking hex nuts

Note to Specifier Any model number higher than LSG-30 will come with a support block.

H. Finish:

- 1. Steel Shop Finish: Apply the following paint system in accordance with manufacturer recommendations and instructions;
 - a. Finish: Hot Dip Galvanized or Powder Coat Safety Yellow
- 2. Stainless Steel products to be mill finish, welds are ground smooth, not polished, and are factory acid washed, neutralized and rinsed.
 - a. No. 2b, products to be mill finish, welds are ground smooth, not polished and are factory acid washed, neutralized and rinsed.
 - b. No. 4 brushed, welds chemically passivated and cleaned.
 - c. No. 6 polished, welds chemically passivated and cleaned.
- I. Packaging: Gate to be fully assembled, with mounting hardware in installation instructions mill cloth bagged and attached to gate.
 - 1. Standard packaging has assembled gate individually packaged in cardboard carton.
 - 2. Exterior of carton to marked with product name, model, size, and finish.

2.5 FABRICATION

- A. Fit and factory assemble items in largest practical sections, for shipment to site.
- B. Fabricate items with joints tightly fitted and secured.
- C. Supply components required for anchorage of fabrications. Fabricate anchors and related components of same material and finish as fabrication, except where specifically noted otherwise.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until mounting substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another subcontractor, notify Architect of uncompleted preparation before proceeding.
- C. Inspect opening for compliance with manufacturer requirements. Verify open conditions are within required tolerances.

Rev. Date: 02.05.21 Page 5 of 6











3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's installation instructions, "Approved for Construction" drawings, shipping, handling, and storage instructions, and product carton instructions for installation.
- B. Tolerances: All dimensional requirements must be in accordance with manufacturer's installation instructions and "Approved for Construction" drawings.
- C. Toeboard on Full Height Safety Gate must be installed with the bottom edge to be <u>no</u> more than ¹/₄" above walking/working surface.
- D. Verify that hinges assemblies operate freely and correctly.
- E. Verify all anchorage is in accordance with manufacturer's installation instructions and applicable data sheets.

3.4 FIELD QUALITY CONTROL

A. Product to be installed using good general construction methods and practices, in accordance with manufacturer's instructions and "Approved for Construction" drawings.

3.5 CLEANING

- A. Touch-up, repair or replace damaged products or components before Substantial Completion.
- B. Clean all surfaces.

3.6 PROTECTION

A. Protect installed products until completion of project.

END OF SECTION

Rev. Date: 02.05.21

